

Specifications FloorBridge® ST 30/30

- Renovation -

General Preliminary Remarks

Preliminary Remarks:

The tendering contractor is to obtain information about the scope of the works to be performed, taking into account the local circumstances before submitting an offer/tender. Concerns about the nature of the works proposed in the tender should be shared with the client in written form. Only one system is to be used. The replacement of individual system parts with those of another system is not permitted. Regulations for accident prevention are to be observed.

Equal quality:

The items list below show products as examples to ensure a uniform floor design and that quality, from a building and processing standpoint, exceeds the relevant minimum requirements. Beyond the properties of the materials, the equivalence also consists of manufacturers' proof of quality control (ISO 9001 certificate) as well as the examinations of colour design, building survey and associated expert reports. In the case of unfilled bidder slots the product examples provided are to be considered offers.

Technical building requirements:

Prior to beginning, all surfaces to be glued must be inspected for workability and suitability. At increased chloride values of the concrete components in the joint area, these defective areas must be treated separately before bonding of FloorBridge joint profiles. This includes the bond strength measurement, compression strength, surface level and residual moisture content. The residual moisture content for bonding the joint profile should be max. 4 %; with increased residual moisture content a suitable adhesive must be used, and the joint profile must be bonded at falling substrate temperatures. The minimum temperature thresholds listed must not be fallen below. If the temperature falls below the dew point bonding and coating works must be stopped. The application must adhere to the curing times stated in the technical data sheets. The concrete substrate must comply with the site-specific requirements and must meet the following minimum values following substrate preparation: tensile bonding strength at least 1.5 N / mm², compressive strength at least 30 N / mm². If the substrate is to be re-profiled, the re-profiling mortar must meet the site-specific requirements and have a minimum compressive strength of 60 N / mm². The substrate must meet technical building standards and requirements, be stable, firm, sufficiently rough, free of cement laitance, dirt, fats, oils, wax, water repellent material or other layers that can prevent or reduce bonding. Generally, following the required substrate preparation the concrete adhesion strength value must reach a minimum of 1.5 N/mm².

Technical requirements reaction resin:

When working with reaction resin-based two or more component materials the minimum temperatures, relative humidity, moisture content of the substrate, mixing-ratio, pot-live, over-coating times etc. must be observed and adhere to, exactly to the figures stated in the manufacturer's technical data sheets.

Demolition waste removal, disposal of empty containers and packaging:

The waste removal from the construction site and the proper disposal of accumulated waste from renovation and restoration measures must be in accordance with the relevant national waste removal directives and is to be included in the unit price. Removing all empty containers and packaging by transferring them to a legitimate, approved waste removal system. These activities must be demonstrated with the appropriate documentation. These costs are to be included in the unit price.

Dishing in the joint area:

When the concrete dishes in the joint area it must be grinded down to the correct height before applying FloorBridge®.

Dishing in the joint area:

When the concrete dishes in the joint area it must be sanded down to the correct height before applying FloorBridge®. Furthermore, there can be no vertical movement in this area.

The technical information in this suggestion has been developed based on the existing experience of the prior art. The texts mentioned are only suggestions for tender and do not substitute the planning responsibility of architects and structural engineers. All information is subject to change.

Installing the joint profile: FloorBridge® ST 30/30

01.0001.

Setting up the construction site

Arrangement of the construction site and technical support as well as all material transport and one time arrival and departure of operatives and clearing the construction site. Necessary electricity costs will be provided on site.

01.0002. Contingency item

Defective steel, aluminium or existing expansion joint profile to be handled as follows:

Removal and disposal of the existing profile (steel, aluminium or other). Next, two cuts will be made about 260 mm apart. The concrete between them (as well as any existing floor covering or resin layers) removed to a depth of ca. 33 – 35 mm for FloorBridge® ST 30/30. This is to be properly disposed of.

If water tightness is required: If a sealing membrane is installed under the joint profile, there must be chiseled out deeper by approx. 5 mm.

A vacuum cleaning device is to be allowed for. The substrate is to be prepared in such a way as to reach a bond strength value of at least 1.5 N/mm² and must be dust-free.

01.0002a. Contingency item:

Defective joint is to be handled as follows:

Removal and disposal of the existing damaged plastic, polyurethane or silicone joint / sealant. Next, two cuts will be made about 260 mm apart. The concrete between them (as well as any existing floor covering or resin layers) chipped out to a depth of ca. 33 – 35 mm for FloorBridge® ST 30/30. This is to be properly disposed of.

If water tightness is required: If a sealing membrane is installed under the joint profile, there must be chiseled out deeper by approx. 5 mm.

A vacuum cleaning device is to be allowed for. The substrate is to be prepared in such a way as to reach a bond strength value of at least 1.5 N/mm² and must be dust-free.

01.0002b. Contingency item:

Making the cavity for FloorBridge®

Making the cavity for the installation of the joint profile by milling or chipping the existing concrete (including any existing floor coverings, resin layers, etc.) in the joint area. The material removed is to be properly disposed of. A vacuum cleaning device is to be allowed for. The substrate is to be prepared in such a way as to reach a bond strength value of at least 1.5 N/mm² and must be dust-free.

01.0003. Contingency item:

Substrate reprofiling with epoxy mortar

If there are larger defects (> 10 mm) in the substrate, these areas must be treated with a bonding coat of a solvent-free epoxy primer. A solvent-free epoxy reaction resin mortar will be immediately applied fresh on fresh onto the primer. The mix ratio and the aggregate grading are to be determined based on the depth of the defects. The compressive strength of the built-in reprofiling mortar must meet the site requirements and have a minimum strength of 60 N/mm².

01.0003a. Contingency item:

Additional layers of epoxy mortar

Additional layers of epoxy mortar (as in the previous item) for additional layer thickness required, priced every 5 mm for additional layers.

01.0004.

FloorBridge® SM 150 - sealing system

Supply and installation of FloorBridge® SM 150, bonded high-performance sealing membrane for sealing existing expansion joints (product data sheet and installation instructions must be strictly observed).

Sealing membrane: FloorBridge® SM 150

Adhesive: FloorBridge® Connect 03

Membrane width: ca. 15 cm

Elongation at break: > 700 % (DIN EN ISO 527-3)

01.0004a.

Vertical bonding FloorBridge - FloorBridge® SM 150 - sealing system

Install sealing membrane as per previous item, vertical bond up to 20 cm on walls, pavements, fenders, etc.

The technical information in this suggestion has been developed based on the existing experience of the prior art. The texts mentioned are only suggestions for tender and do not substitute the planning responsibility of architects and structural engineers. All information is subject to change.

01.0005.

Joint profile FloorBridge® ST 30/30

FloorBridge® ST 30/30, prefabricated polymer floor joint profile in carbon fiber composite technology, sandable, highly resilient and viscoelastic; supply and install (according to manufacturer specifications).

Installation and glueing FloorBridge® ST 30/30 with proven two component epoxy resin adhesive. If necessary, alignment of the joint area between the joint profile and the concrete surface with proven two component epoxy resin adhesive.

After the adhesive has hardened a diamond rotary sander will be used to sand the FloorBridge® joint profile.

Characteristics: metal-free, therefore non-corrosive

Expansion coefficient: similar to resin floors

Joint profile width: ca. 250 mm

Joint profile thickness: ca. 30 mm

Horizontal joint movement total: 25 mm (-5/+20 mm)

Sandable: max. 6 mm

Bonding adhesive: FloorBridge® Connect 03

Compression strength: 65 N/mm² (ONR 23303)

Bending tensile strength: 50 N/mm² (DIN EN 196-1)

Colour: grey

01.0005a. Contingency item:

Support pillars

Surcharge for difficulty in support pillar area. The **FloorBridge®** joint profile is to be adapted to the shape of the support pillar.

01.0005b. Contingency item:

Mitre cuts

Surcharge for making mitre cuts in areas with a change in direction.

01.0005c. Contingency item:

FloorBridge® ST 30/30, - Surcharge for T-shaped part

Surcharge for producing and installing a T-shaped part

01.0005d. Contingency item:

FloorBridge® ST 30/30, - Surcharge for angle-shaped part (90° angle)

Surcharge for producing and installing an angle-shaped part (L-shaped part)

01.0005e. Contingency item:

FloorBridge® ST 30/30, - Surcharge for cross-shaped part

Surcharge for producing and installing a cross-shaped part

01.0006

Transparent or coloured sealing

A transparent or coloured reactive resin sealer is applied to the prepared joint profile surface. The sealer must match both, the neighbouring surface coating (necessary slip and abrasion resistance, etc.) and FloorBridge®.

It is important to ensure that the sealing is removed from the grout. The grout must be cleared in order to not restrict the maximum elongation. In general, the specifications given by the manufacturer are to be observed.

01.0007. Option for watertightness**FloorBridge® SM 150 - sealing system**

Delivery and installation of FloorBridge® SM 150, bonded high-performance sealing membrane for sealing existing expansion joints (product data sheet and installation instructions must be strictly observed).

Sealing membrane: FloorBridge® SM 150

Adhesive: FloorBridge® Connect 03

Membrane width: ca. 15 cm

Elongation at break: > 700 % (DIN EN ISO 527-3)

01.0007a. Option for watertightness**Vertical bonding FloorBridge - FloorBridge® SM 150 - sealing system**

Install sealing membrane as in the previous option, vertical bond up to 20 cm on walls, pavements, fenders, etc.